

Memorandum

To:

From:

Date:

Re: TV Compound Facility Power Verification

I confirm that _____ located at _____

Does have the power requirements listed below as stated in the NCAA Broadcast Manual and Policies to provide electricity to the television trucks.

Power requirements (TV compound). Three dedicated services of power (all three phase and 208 volts) for mobile A-unit (400 Amps), B-unit (200 Amps) and satellite uplink truck (100 Amps) shall be available for all NCAA championships live telecasts. An area for parking the mobile unit will be available within 150 feet of the power service closest to the anticipated camera positions or announce booth. This designated area should provide enough room for two TV production trucks 65 feet long by 25 feet wide. There must be room for a third vehicle (Uplink truck) to park in close proximity (within 100 feet) to the primary mobile unit. In addition, the primary television entity must have adequate space in the television compound to install up to three production work trailers. Each trailer requires 220 volt, single phase and 100 amps per leg. If a facility meets all the requirements to host an NCAA championship, but does not have television adequate power, the host site may agree to provide necessary power by means of generators at the expense of the venue, LOC or host school.

Does not have the power requirements to provide electricity to the television trucks.

Additional Comments: