

**NCAA TV Compound Facility Power Verification (excluding DI Women's Basketball)
FORM**

Name: _____

Phone and Email: _____

School: _____

Signature: _____

I confirm that _____ located at

☐

DOES have the power requirements listed below to provide appropriate electricity to the television trucks.

Power requirements (TV compound).

One Truck Event + Uplink

Minimum = (1) 200 A, three-phase at 208V + 1 100 A, one-phase at 208V

Two Truck Event + Uplink

Minimum = (2) 200 A, three-phase at 208V + 1 100 A, one-phase at 208V

If a generator is required, it shall be a dual twin pack, crystal sync with operator; and the operator shall stay with such generator from hook up to power down. ESPN will provide NCAA with the name and contact information of its pre-approved third-party generator supplier/operator for such Pre-Determined Site Games or World Feed Games and the NCAA shall use Commercially Reasonable Efforts to engage (or shall use Commercially Reasonable Efforts to cause the applicable venue site operator at the Pre-Determined Site Game or World Feed Game to engage) such approved supplier/operator for any applicable generator needs.

☐

DOES NOT have the power requirements to provide electricity to the television trucks.

Additional Comments: